

Monthly Bacteria Testing

Date Collected	Total Coliform	E.coli	Address	Total Coliform	E.coli	chlorine	Results are in parts per million MPN/100 mL
1/8/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.20	
2/8/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.39	
3/9/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.24	
4/14/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.37	
5/5/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.38	
6/9/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.05	
7/7/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.20	
8/6/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.10	
9/13/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.10	
10/6/2021	1.0	<1.0	118 Main St.	<1.0	<1.0	0.04	
11/3/2021	2.0	<1.0	118 Main St.	3.1	<1.0	0.20	
11/5/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.70	extra samples due to Nov. test results
11/5/2021			116 Main St.	<1.0	<1.0	0.10	extra samples due to Nov. test results
11/5/2021			126 Main St.	<1.0	<1.0	0.30	extra samples due to Nov. test results
12/6/2021	<1.0	<1.0	118 Main St.	<1.0	<1.0	0.04	