

Water testing schedule and results

Date	Lead	Copper	ug/l
6/28/2017	5.58	51.07	
6/28/2017	6.2	85.01	
6/27/2017	0.89	361.3	
6/28/2017	3.97	121.2	
6/27/2017	3.71	52.08	
6/2/2020	7.481	45.68	
6/2/2020	3.209	71.37	
6/2/2020	11.55	11.64	
6/2/2020	ND	769.1	
6/2/2020	2.873	348.2	
All five locations are within acceptable limits			